

TEST CERTIFICATE

CT-2021-02-25-02

Product: HPL Starline A210 ECO
Thickness: 0.8 mm, coated on one side

Company: DI Dekodur International
GmbH & Co KG
Langenthaler Str. 4
69434 Hirschhorn Neckar

Order: Determination of emission of volatile organic compounds (VOC) and formaldehyde from a HPL according to AgBB-Scheme 2018, ISO 16000 parts 3, 6 and 9, DIN EN 16516 (01/2018)

Test method: Test chamber method and analytics according to AgBB- Scheme 2018 DIN EN 16516 (01/2018)

Test report: 2520398/2 dated 2020-09-30

Test result: The tested product „Starline A210 ECO“ meets the demands of the AgBB-Scheme.

Dresden, 2021-02-25

Head of laboratory



Engineer in charge